

## Original Research Article

### Predictive Modeling for Parametric Analysis of an Air Conditioning System in a 400-seat Auditorium in Warri, Sub-tropical Nigeria

**Abstract-** Considering the fact that Nigeria-Warri is located in the sub-tropical region of Nigeria which is characterized by excessively ly high temperature and highly humidity, made-it is necessary to develop an air-conditioning system which can reduce the hot and ambient temperature within a confined space for human comfort. The-This research is basically presents a-the design of an air-conditioning system for comfort of occupants in a 400-Seater auditorium. The three independent variables considered for this design are: the number of occupants, air exchange rate and the outdoor temperature. The auditorium was properly measured and the heat generated by the bulbs, appliances and occupants were adequately considered to get the total-required cooling load. The-calculated-cooling-load-was-determined-and-a-regression.-Regression analysis was used to predict-carried-out-to-obtain-a-regression-or-predictive-model-which-was-used-to-and determine the predicted cooling load. Optimization analysis was also done to determine the optimal condition for maximum cooling load. The plant capacity that will provide thermal comfort for the 400 occupants was calculated to be 25<sup>TR</sup>.

**Keywords:** *Air-conditioning system; parametric analysis; predictive model; optimization; temperature; heat.*

#### 1.0 Introduction

Air conditioning can be explained as any process that alters the properties-of-air-(primarily humidity and temperature))-of indoor air to favorable conditions, typically with the aim of distributing the conditioned air to a space that is occupied in other to improve comfort. Air conditioning is any type of technology used for cooling, cleaning-purifying, humidificationhumidifying, heating, ventilation-ventilating, de-humidification-de-humidifying or movement-moving-of-air, that-modifies-modifying-its temperature of air (Marderos & Mohammad, 2011; Bansal et. al., 1996; Franck et. al., 2015).

In general, an air conditioner is a mechanical device that lowers the air temperature. The cooling is mostly done using-through a simple refrigeration cycle, but sometimes the-by evaporation is-used, commonly for the comfort-of cooling in-of buildings and motor vehicles (Jadhav & Lele, 2015; Wufeng et. al., 2015; Pankaj et al, 2015). In its simplest form, a complete system of heating, ventilation /air conditioning is referred to as heating, ventilation and air conditioning (Shahi *et. al.*, 2016; Onoroh et al, 2013; Duarte et al, 2017). Air conditioning can be provided also by the simple process called free cooling which uses pumps to circulate a coolant from a cold source, which in turn acts as a heat sink for the energy that is removed from the cooled space (Edward et. al, 2011; Diaz et al, 2020; Mohamed & Alnahhal, 2019).

Generally, air conditioners can be classified into window unit air-conditioners, central unit air-conditioner, and split unit air-conditioner (Yujin et al, 2017; Khurmi & Gupta, 2008; Prathibha et. al., 2017). The various components of a window unit air conditioner, e.g. condenser, expansion valve, compressor, evaporator and cooling coil are designed in as a single system unit. This type of air conditioning unit is usually placed on-in a open-wall opening whereby interior air is cooled as a fan blows it over the evaporator. On-the-outside-of-the-air-conditioning-unit,-the-The heat extracted from the inside is discharged to the outside environment as the second fan outside blows outdoor air over the air condition system condenser. For large buildings with several rooms, each room can be made to have a cooling unit allowing cooling of each room separately.

Comment [d1]: power plant?

Comment [d2]: in full

Comment [d3]: ???

The central unit conditioner is preferred for cooling big building houses, offices, entire hotels, cinema halls, and factory-factories, etc. The central unit air conditioner is made of huge compressor that has the capacity to produce tons of conditioned air-conditioning. Split unit air conditioning system comprises of two parts; the outdoor unit and indoor unit. The outdoor unit fitted outside the-a room is housing-houses components like the compressor, condenser, and the expansion valve. The indoor unit comprises the evaporator, and cooling fan. Considering that Nigeria-Warri is located in the sub-tropical region of Nigeria characterized by excessive temperature and highly humidity, it became necessary to design an air conditioning system which can help reduce the hot ambient temperature within a confined space for human comfort. In this research work, the parametric analysis of an air conditioning system for a 400 seat capacity auditorium in Warri was carried out.

Comment [d4]: ...you mean residential?

Comment [d5]: source?

Comment [d6]: source?

## 2.0 Methodology

### 2.1 Problem Description/Assumptions

The air conditioned auditorium is to be maintained at comfort condition of 22 °C DBT and 65 – 55% R.H. The number of occupants and the ambient condition varies in the following order:

Comment [d7]: what is the justification for this?

Comment [d8]: all abbreviations should appear in full first time used

- Number of occupants;  $\theta$ —400 persons
- Outdoor Temperature: (29 – 41 °C) DBT and (25 - 32°C) WBT
- Air exchange rate: 0.46 – 0.54 [ACH]

The ventilation requirement inside the auditorium is such that 55% of the return air is re-circulated and mixed with 45% of the make-up air after the cooling coil. The condition of air leaving the cooling coil is to be maintained at 14 °C. Seating capacity of the auditorium is 400 persons.

Comment [d9]: how and why?

Sensible heat given per person and the latent heat gain per person are assumed to be 320 kJ/hr and 100 kJ/hr respectively. The inside condition varies in accordance with the degree of activity of the occupants and intended use of the auditorium.

Comment [d10]: on what basis was this assumption made?

The following response functions can be considered: total cooling load (Watt); cooling coil capacity (TR); and amount of water removed by dehumidification ( $kg/s$ ).

The system is represented in block diagram as Figure 1. The block diagram description of the problem is given in Figure 1(a) followed by an equivalent representation on the psychrometric chart in Figure 1(b).




Figure 1(a): Block diagram representation of the auditorium air-conditioning problem.



developed for a range of the input variables called the central composite design (CCD). The design optimization study is intended to reveal the optimal plant capacity required to achieve the desired comfort of the occupants of the auditorium. The three key input variables were considered at the levels described in Table 1. The CCD template is presented in Table 2. Both the experimental design and the statistical analysis were implemented on model-based calibration (MBC3.3) toolbox found in MATLAB (R2007b). The modeling utilized a quadratic model of the generalized form presented in equation 1.

$$f(X_j X_j) = \beta_0 + \sum_{j=1}^k \beta_j X_j + \sum_{j=1}^k \beta_{jj} X_j X_j + \sum_{i < j=2} \sum \beta_{ij} X_i X_j + \varepsilon \quad (5)$$

Where,  $f(X_j X_j)$  is the objective function,  $\beta_0$  is the model intercept,  $k$  is the number of design variables.  $X_j$ ,  $X_j X_j$  and  $X_i X_j$  represent the first-order term(s), the second-order term(s), the interaction term(s) of the model, respectively.  $\beta_j$ ,  $\beta_{jj}$  and  $\beta_{ij}$  are the respective coefficients of the model terms.  $\varepsilon$  is the random error of prediction.

Table 1: Design points indicating the levels at which the independent variables were observed

Design variables ( $X_i, i = 1, 2, 3$ )	Levels of independent variables				
	$-\alpha$	$-1$	$0$	$1$	$\alpha$
Number of occupants, $X_1$	0	81	200	319	400
Outdoor temperature, $X_2$ ( $^{\circ}\text{C}$ )	29	31.4	35	38.6	41
Air exchange rate, $X_3$ (ACH)	0.46	0.48	0.5	0.52	0.54

Table 2: The CCD template in coded notation

S/N	$X_1$	$X_2$ $^{\circ}\text{C}$	$X_3$	$Y(W)$
1	0	0	0	$Y_1$
2	0	0	0	$Y_2$
3	0	0	0	$Y_3$
4	0	0	0	.
5	-1	-1	-1	.
6	1	-1	-1	.
7	-1	1	-1	.
8	1	1	-1	.
9	-1	-1	1	.
10	1	-1	1	.
11	-1	1	1	.
12	1	1	1	.
13	$-\alpha$	0	0	.
14	$\alpha$	0	0	.
15	0	$-\alpha$	0	.
16	0	$\alpha$	0	.
17	0	0	$-\alpha$	.
18	0	0	$\alpha$	$Y_N$

### 2.3 Design optimization via genetic algorithm

The genetic algorithm (GA) is an evolutionary method for solving both constrained and unconstrained optimization problems that is based on the principle of natural selection. The algorithm starts with an initial population representing nominal individual solution. The genetic algorithm repeatedly modifies the population. At each step, the GA selects individuals at random from the current population to be parents and uses them to produce offspring for the next generation following three major genetic operators including; Selection, Crossover and Mutation.

Selection rules select the individuals, called parents that contribute to the population at the next generation based on the resulting fitness value. Crossover rules combine two parents to form children for the next generation. Mutation rules apply random changes to individual parents to form children. Over successive generations, the population "evolves" toward an optimal solution. GA can be applied to solve a variety of optimization problems that are not well suited for standard optimization algorithms, including problems in which the objective function is discontinuous, non-differentiable, stochastic, or highly nonlinear. The implementation and result using the genetic algorithm will be presented and discussed in chapter four.

Comment [d14]: section 4???

## 3.0 Results and Discussion

### 3.1 Experimental design and statistical modelling

The study basically involves calculation of the total cooling load (TCL) of the auditorium at operating condition as presented in Table 3. To this end, the contributions to the total sensible heat (TSH)/the total latent heat (TLH) resulting from human activities, the available facilities and infiltrations, calculated at various operating conditions prescribed by the experimental design were added up to obtain the calculated TCL,  $Y(W)$ .

The information obtained for the observed eighteen data points were clearly not sufficient to describe completely the behavior of the system, thus further statistical analysis via mathematical model was conducted. The quadratic model presented in equation 5 was fitted to the input – output data set. Following the least squares approximation method, the unknown constant and coefficient terms of the fitting function were determined to obtain the actual predictive model for the total cooling load presented as equation 6. The total cooling load was also evaluated via the predictive model at the DOE test conditions and the results (Predicted Y) were juxtaposed with the calculated TCL (Y) in Table 3.

$$Y(X_1^2, X_2^2, X_3^2) = 32485.2373 + 116.66X_1 - 22914.58X_3 + 1041.67X_2X_3 + 0.0000118X_1^2 \quad (6)$$

Table 3: Calculated and predicted cooling load at some selected design points using the CCD

S/N	$X_1$	$X_2 \text{ }^\circ\text{C}$	$X_3$	$Y(W)$	Predicted_Y(W)
1	200	35	0.5	62590	62590.21
2	200	35	0.5	62590	62590.21
3	200	35	0.5	62590	62590.21
4	200	35	0.5	62590	62590.21
5	81	31.4	0.48	46636	46636.03
6	319	31.4	0.48	74403	74402.97
7	81	38.6	0.48	50236	50236.03
8	319	38.6	0.48	78003	78002.97
9	81	31.4	0.52	47028	47027.78
10	319	31.4	0.52	74795	74794.72

<b>11</b>	81	38.6	0.52	50928	50927.78
<b>12</b>	319	38.6	0.52	78695	78694.72
<b>13</b>	0	35	0.5	39257	39257.11
<b>14</b>	400	35	0.5	85924	85924.25
<b>15</b>	200	29	0.5	59465	59465.21
<b>16</b>	200	41	0.5	65715	65715.21
<b>17</b>	200	35	0.46	62049	62048.46
<b>18</b>	200	35	0.54	63132	63131.96

Table 4: Model summary of statistics

Observations	18
Parameters	5
Box-Cox	1
RMSE	0.261
$R^2$	1
$R^2$ Adjusted	1
$PRESSR^2$	1

The performance of the resulting model was first evaluated using the resulting summary of statistics (SOS) for the model presented in Table 4. The SOS reflects high prediction accuracy of the model. The  $R^2$ , the *adjusted*  $R^2$  and the  $PRESS R^2$  all stand at maximum value of 1. These are indications that 100% of the overall system behavior can be predicted via the predictive model within the range of input variables. The result of maximum  $R^2$  value of 1 is valid in this case since the original response data were obtained by calculation using existing theoretical relationships and not from experimentation. Thus, random error usually associated with experimental irregularities was totally avoided. The RMSE value is sufficiently close to zero. This also suggests that the prediction error was adequately minimized. Moreover, there is no indication of over-fitting of the model. The high prediction accuracy of the quadratic model is further illustrated by the agreement witnessed between the predicted response and the calculated response over the entire design space as recorded in both Table 3 and Figure 2.




Figure 2: Comparison of the calculated and predicted response

### 3.2 Interaction effects of the design variables

Looking at the results holistically an overall linear interaction were observed. For various significant interactions presented, two factors were varied simultaneously while the third factor is kept at its mean value. The combined effects of the number of occupants and outdoor temperature on the predicted total cooling load are presented in Figure 3. From the results, the number of occupants appears to be the most influential factor for the studied range of parameters. The TCL was found to increase progressively along a straight line while both the number of occupants and the outdoor temperature were increased at mean air exchange rate. This observation agrees with the intuition that higher cooling efforts (or greater plant capacity) will be required to maintain cooling comfort for increased number of occupants or increased outdoor temperature.




Figure 3: Combined effects of the number of occupants and the outdoor temperature on the predicted total cooling load




Figure 4: Combined effect of the outdoor temperature and the air exchange rate on the predicted total cooling load

Similar results were recorded with respect to the interactive effects of the outdoor temperature and the natural air exchange rate as shown in figure 4. However, the outdoor temperature condition show relatively greater effect on TCL compared to air exchange rate. The overall result suggests that maximum TCL could be obtained towards the positive axial points of the three design variables.

### 3.3 Prediction of optimal cooling load via Genetic Algorithm (GA)

In order to specify the appropriate plant capacity that would guarantee occupants' comfort in the auditorium over a wide range of ambient condition and human activities, the optimal cooling load must be evaluated. Thus, maximization of the total cooling load,  $Y$  was considered a major design objective. The response  $Y$  was identified as a function of three independent variables including; the number of occupants  $X_1$ , the outdoor temperature  $X_2$  and the air exchange rate  $X_3$  which are considered the design variables. The optimization study was implemented in global optimization toolbox found in MATLAB. The steps involved include; selection of optimization algorithm, calling of the fitting function via the function handle, setting of the number of variables, specification of the boundary points and the algorithm specific parameters.

The GA specific optimal parameters utilized in the study are: crossover fraction '0.9'; rosover function scattered; mutation function 'adaptive'; population size '100'; engeration '100'.

The predicted optimal solution is presented in Table 5.

Table 5: Predicted optimum condition for maximum cooling load

$X_1$	$X_2$ °C	$X_3$ (ACH)	$Y$ (W)
390	38.2	0.52	86851.5

From the predicted optimal cooling load,  $Y_{optimal}$ , the optimal plant capacity in tons of refrigeration is given by;

$$\frac{Y_{optimal}}{3500} = \frac{86851.5}{3500} = 24.81TR \quad (7)$$

Considering reasonable design tolerance, the installed capacity of the air conditioning plant should be 25TR.

### 4.0 Conclusion

The design of an air-conditioning unit for a 400 seat capacity auditorium was successfully carried out. A plant of 25TR capacity was recommended for the auditorium to guarantee occupants comfort over a wide range of operating conditions. Although the number of occupants appears to be the most important variable, the two other identified system variables including; outdoor temperature and natural air exchange rate equally have considerable effects on the total cooling load of the auditorium. A mathematical model for predicting the total cooling load for the proposed auditorium air conditioning project at typical design condition was developed and the optimal plant capacity for the proposed auditorium air conditioning project was determined.

Comment [d15]: this is not in the paper

Comment [d16]: this was not stated in the paper

### References

- Bansal P.K., Rupasinghe A.S., Jain A.S. (1996). An empirical correction for sizing capillary tubes. *Int. Journal of Refrigeration*, 19(8): 497–505.
- Duarte M.V, Pires L.C, Silva P.D, Gaspar P.D. (2017). Experimental Comparison between R409A and R437A performance in a heat pump unit. *De Gruyter Open*, 7: 77-90.

- Diaz T.Y., Alvarez G.M.A., Haeseldonckx D. (2020). The air conditioning systems. Brief review of the main characteristics. Part 1: *Universidad Y Sociedad*, 12(1): 53-63.
- Edward G.P., (2011) Air Conditioning principles and systems, 3rd edition, Eastern economy edition.
- Franck L., Pascal O., Mathieu D., Frantz S., Boris B., Fabien P., (2015). A Method To Evaluate Energy Performance Of Buildings Cooled By Room Air Conditioners. *The 7th International Conference On Applied Energy – Icae*, 1275 – 1283.
- Khurmi R.S., Gupta J.K. (2008). A Textbook of Thermal Engineering, New Delhi, S.Chand, 824-825.
- Marderos A.S., Mohammad H.Z.F. (2011). Comparison of two methods of improving dehumidification in Air-conditioning Systems: hybrid system (refrigeration cycle – rotary desiccant) and heat exchanger cycle. *Energy Procedia*, 6: 759–768.
- Mohamed E. & Alnahhal M. (2019). Central air conditioning: Systems and application. *Intech Open* (Open access books).
- Onoroh F., Chukwunke J.L., Itoje H.J. (2013). Performance Evaluation of a Thermoelectric Refrigerator. *International Journal of Engineering and Innovative Technology*, 2(7): 18 – 24.
- Pankaj D., Gagandeep S.S., Rajesh G. (2015). To Optimize the Effect of Various Parameters on the performance of vapor compression Refrigeration cycle. *International Journal of Engineering Research & Technology (IJERT)*, 4(7): 1219 – 1225.
- Prathibha V.V., Bharathi A.K., Busi A.K., Naga D.V.V. (2017). Design of Air-Conditioning(a.c) System for Residential/Office Building. *International Journal of Emerging Research in Management & Technology*, 6(3): 17-19
- Shahi S., Sucheta J., Sanap A., Patil, S. (2016). Design and Development of Portable Air Conditioner. *International Journal for Research in Engineering Application & Management*, 2(7): 31-35
- Wane S.S., Nagdeve M.B. (2012). Design of Air Cooling System for College Auditorium, *Journal of Environmental Research and Development*, 6(3): 562 – 568.
- Wufeng J., Yafei Z., Yan Z., Yuebo J. (2015). Experimental study of factors affecting the performance of a semi-enclosed outdoor air-conditioning unit, the 9th international symposium on heating, ventilation and air conditioning (ishvac). *Procedia Engineering*, 121: 1713–1720.
- Yueqin Z., Xinwei W., Jing Z., Zhixin P. (2017). Study on the design schemes of the air-conditioning system in a gymnasium. *IOP Conf. Series: Earth and Environmental Science*, 81:012158.