

1
2
3
4
5
6
7
8
9

ECONOMIC ANALYSES OF INTEGRATING SOLAR INVERTER INTO THE EXISTING ENERGY SYSTEMS IN NIGERIAN HEALTHCARE CENTERS

ABSTRACT

Reliable electricity supply is crucial towards efficient healthcare delivery in a developing country like Nigeria, where national grid faces constant outages. Many healthcare centers depend on diesel generators, meaning high operational costs and environmental impacts. This study investigates the economic feasibility of integrating solar photovoltaic (PV) systems with existing energy infrastructure at a healthcare facility in Nigeria. Data were collected from a healthcare facility among others, and, using HOMER software; three different system configurations were simulated over a 25-year project lifetime, with focus on incorporating solar inverter system, alongside existing grid supply and generator. Results showed the optimal system configuration to be the one comprising of solar inverter system alongside the existing grid and diesel generator. This system has a significantly lower net present cost (NPC) of \$382,263, compared to the base case scenario of \$1,663,158, which relies totally on grid electricity and the diesel generator. The levelized cost of energy (LCOE) for the hybrid system is \$0.139/kWh, also much lower than base case LCOE of \$0.642/kWh. While initial investment cost for this system posed a challenge, the study demonstrated a payback period of approximately 4.8 years, with return on investment of 16%, and an internal rate of return (20.3%). The findings demonstrated the economic viability and potential benefits of integrating solar PV systems in the healthcare sector, as energy costs are lowered due to reduced billing and maintenance costs. This has significant potential for long-term cost savings, in addition to elimination of havoc-causing outages. Furthermore, reduced dependence on diesel generator implies lowered greenhouse gases emission, which is beneficial to patients, staff and visitors. Government incentives or other financing mechanisms are potential solutions to high installation costs. This research is recommended for implementation in places like Nigeria, as it serves as a guide towards sustainable energy for improved healthcare delivery.

10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28

Keywords: [Solar photovoltaic, Healthcare, Software, Energy storage, Renewable energy.]

1. INTRODUCTION

Sustainable growth necessitates that energy supply be affordable and consistent [1]. Nigeria's healthcare system is faced with a number of challenges, first of which is lack of reliable power supply [2]. Unstable and inadequate electricity supply in Nigeria makes the problems currently experienced by healthcare facilities worse due to interruptions of vital medical services which jeopardize patient care, in addition to making storage of vaccinations and prescription drugs very difficult [3]; [4]. This often hinders developments and causes loss of lives in extreme situations. Most health-care centers often fall back to diesel generators, whose high cost of maintenance weighs down their already stretched budgets [5]. Addressing these energy challenges in the healthcare sector is crucial for ensuring sustainable healthcare delivery and achieving better health outcomes for the Nigerian population. Integrating solar PV together with energy supply from national grid may serve as one of the potential solutions to the energy challenge [6]. Solar energy is one of the most promising sources of renewable energy in Nigeria due to its apparent abundance. Solar

29 generating potential of Nigeria is about 7.1Kw/m²/day, featuring as one of the highest in
30 Africa [7]. Energy radiated from the sun is about 3.8 x 10²³ kW, which is 1.082 million tons of
31 oil equivalent (mtoe) per day. This is about 4000 times the current daily crude oil production
32 in Nigeria, and about 13,000 times the natural gas daily production, based on standard
33 energy units [8]. Solar photovoltaic (PV) adoption in Nigeria has been steadily increasing in
34 recent years, making it promising towards the actualisation of Nigeria's Sustainable
35 Development Goals, SDGs [9]; [10]. Solar inverters are responsible for converting Direct
36 Current (DC) output produced by solar panels into Alternating Current (AC) electricity,
37 making it compatible with the national grid or local networks [11]. The conversion process is
38 essential for enabling the integration of solar energy into existing energy infrastructures,
39 ensuring its usability for various applications [12]. The role of solar inverters is critical in
40 enhancing operational and technical performances of solar power plants and stabilizing the
41 output of solar power systems [13]. This capability for voltage conversion and stabilization
42 not only enhances the efficiency of solar energy utilization, but also contributes to the overall
43 stability and resilience of the electrical grid [14]. In the mid-80s, introduction of grid-
44 connected PV systems led to further development of solar inverters alongside output and
45 efficiency [15]. Technological advancement also facilitated the development of complex
46 inverters, such as the Maximum Power Point Tracking, MPPT inverters [15]. Towards the
47 end of last millennium (1990s), more economical PV systems for residential areas came to
48 existence with the introduction of transformerless inverters [16]. Moreover, versatility of solar
49 batteries led to the creation of hybrid inverters, which can control both solar power
50 generation and battery storage, making homes and businesses more energy independent
51 [17]. While solar energy has been the primary focus of this study, it is essential to reflect on
52 the potential contributions of other renewable energy sources in Nigeria's energy transition.
53 Research findings have investigated the prospects of biomass energy in Nigeria, particularly
54 from agricultural residues and municipal solid waste [18]. By leveraging on Nigeria's
55 abundant biomass resources, it was indicated that the country can make significant strides
56 towards achieving its renewable energy targets, and, reducing heavy reliance on fossil fuels.
57 In the context of Nigeria's energy sector, fossil fuels reign supreme, contributing over 80%
58 of the national grid's electricity [19]. In spite of this heavy reliance on fossil fuel, out of a total
59 population of about 162million people, up to 40% of these Nigerians do not have access to
60 electricity [20]. Energy is of paramount importance, as it is widely useful in all aspects of
61 human endeavour for technological advancements, and can exist in several forms [21]; [22].
62 In its own case, solar energy is sourced from arresting sun's radiant energy and afterwards
63 converting it into heat and electricity, among others [22]. Solar PV systems hold significant
64 importance in healthcare settings due to their potential to enhance energy efficiency, reduce
65 operational costs, and improve access to healthcare services. Moreover, solar energy
66 systems contribute to mitigating environmental pollution and reducing carbon emissions,
67 thus promoting a healthier environment for patients and staff. Recent findings highlighted the
68 positive impact of solar energy adoption in healthcare facilities, especially for sustainability in
69 resource-limited settings [23]. Although investment decisions are affected by upfront costs,
70 operating expenses and revenue, economic sustainability of energy storage integration is
71 still being debated [24]. Therefore, thorough cost-benefit studies are necessary in order to
72 evaluate the financial implications of energy storage projects to be able to advise investors,
73 project developers and legislators. A recent study analyzed the cost-effectiveness of the
74 grid-connected energy storage systems in mitigating peak demand and reducing consumer's
75 electricity costs [25]. Furthermore, the importance of a holistic assessment involving financial
76 viability and environmental benefits has been emphasized [26]. Several other researchers
77 have made significant findings on solar systems integration. For instance, a recent study on
78 economic analysis of integrating solar inverters in residential buildings demonstrated
79 significant long-term savings and payback periods [27]. Another study that analyzed the
80 economic viability of solar PV systems across different regions of Nigeria revealed significant
81 regional disparities, with the northern regions demonstrating higher economic potential due

82 to higher solar irradiance levels and relatively lower component costs compared to the
83 southern regions [28]. Some authors have also stressed the need for a stable and consistent
84 policy framework to provide the necessary regulatory certainty that will encourage long-term
85 investments in solar energy infrastructure [29]. Moreover, in recent times, a hybrid of
86 renewable energy systems, comprising of solar and wind was reviewed [30], [31]. While a
87 group of researchers investigated integrating solar energy with home micro grid [32], another
88 set similarly looked at integrating solar photovoltaic energy systems for industrial and
89 commercial power consumption [33]. As most studies analyze standalone solar PV systems,
90 research directly exploring the economic feasibility of integrating solar with existing energy
91 infrastructure systems in healthcare facilities is scarce. Moreover, grid electricity tariffs can
92 differ considerably across Nigerian regions. Most researches do not always account for this
93 regional variation, leading to potentially inaccurate economic assessments. More studies are
94 needed that incorporate location-specific energy costs into the Cost-Benefit Analysis (CBA)
95 for solar integration projects. Thus, this study was centered on providing useful insights for
96 decision-makers in the public and private sectors, by evaluating the costs of purchasing,
97 installing, and maintaining solar inverters alongside current energy infrastructure. It also
98 evaluated potential savings derivable, when reliance on traditional energy sources and grid-
99 supplied electricity become reduced. Therefore, the study was aimed at conducting an
100 economic analysis which involved combining existing energy production and storage
101 systems with solar inverters at a health care center. Hence, the objectives of this study
102 include (i) Assessing the economic feasibility of integrating solar inverters into healthcare
103 facilities in Nigeria by analyzing initial investment costs, operational expenses, and potential
104 energy savings associated with solar energy adoption. (ii) Evaluating the technical feasibility
105 of integrating solar inverters with existing energy systems in healthcare facilities, considering
106 energy consumption patterns and backup power requirements. (iii) Investigating the potential
107 economic benefits of solar inverter integration in healthcare facilities in Nigeria. In terms of
108 justification, installing solar inverters alongside energy supply from national grid in medical
109 centers will guarantee an improved supply of electricity for critical medical equipment,
110 vaccine and drug refrigeration, emergency lighting, and life-saving medical supplies.
111 Additionally, solar inverter integration has potential for lowering short- and long-term energy
112 expenditures; providing a viable and affordable substitute for diesel generators, which are
113 frequently utilized as backup power sources.

114
115

116 **2. METHODOLOGY**

117 The procedures for identifying, obtaining data and analysing collected data are as presented
118 in this section. To start with, alongside the healthcare facility being studied, some of the
119 equipment and materials used include: log book, solar resources data, costs record book,
120 electricity bills due to national grid supply, records on diesel generator's maintenance and
121 fueling.

122 **2.1 Setting**

123 This study was focused on a privately-owned healthcare facility in Ikeja, Lagos State,
124 Nigeria.

125 **2.2 Data Collection**

126 Historical data on daily load consumption was collected at the facility. For this, the hourly
127 load profile data for a 24-hour period was obtained, capturing the facility's energy demand at
128 different times of the day. The quantitative data used were collected through primary and
129 secondary methods. Collection of primary data was by means of a walk-through audit of the
130 facility [34] to determine the energy consumption of the medical equipment and other
131 devices therein.

132 Historical resource data, including the monthly averages of solar Global Horizontal
133 Irradiance (GHI) and temperature data for the facility's location was acquired from

134 government resources and solar resource data bases of the National Renewable Energy
 135 Laboratory Database. Relevant technical specifications and cost information for various
 136 system components, such as solar PV panels, batteries, converters, and diesel generators,
 137 were collected through market research. The secondary data were obtained by assessing
 138 the facility documents and market research to gather information on equipment lifespan,
 139 costs of Solar PV components and assembly. Information on various solar PV components
 140 specifications was also obtained.

141 **Table 1. Information Collectable from Energy Audits (Source: [34])**

S/n	Information generated	Definitions
1	Process flowchart	A diagram that shows the sequence of operation
2	Equipment schedule	The collation of every used equipment.
3	Load summary	This is a concise summary of total load of each equipment class used in the factory and also the total load as well as the number of all the appliances in factory, it gives a quick look at what the heavy-duty appliances are.
4	Load distribution chart	This is graphical representations of the load summary via pie chart. It shows the relationship between each equipment and their loads
5	Energy consumption chart	This is a bar chart and pie chart representation of the energy consumption pattern, it shows the relationship between each equipment class and their energy consumption
6	Load intensity chart	Sets of charts that determines what the load intensive space/room are in the factory, by comparing the amount of load in each space to the area of the space
7	Energy intensity chart	Sets of charts that determines what the energy intensive space/room are in the factory, by comparing the daily, weekly or monthly energy consumption of each space to the area of the space
8	Peak load profile	The peak load curve is a graphical representation of the load to time period relationship of peak load equipment (equipment connected for both short and long periods of time). It gives a snapshot of energy consumption per time period in a day of peak load Equipment.
9	Base load profile	The base load curve is a graphical representation of the load to time period relationship of base load equipment (equipment connected for a long period of time). It gives a snapshot of energy consumption per time period in a day for base load equipment
10	Load profile (Base and Peak Load)	Chart that compares the base load profile and peak load profile.

142 To accurately model and analyse the energy system integration, an understanding of the
 143 healthcare facility's energy consumption patterns was essential. Following the information

144 available in Table 1, data were collected during the walk-through audit of the healthcare
145 facility for energy consumption analysis.

146 The following steps were undertaken to conduct the energy consumption analysis:

147 *1. Load Profile Data Collection*

148 Historical hourly load profile data for a typical 24-hour period was collected from the
149 healthcare facility. This data captured the fluctuations in energy demand throughout the day,
150 allowing for the identification of peak demand periods and overall daily energy consumption
151 patterns.

152 *2. Load Characterisation*

153 The collected load profile data was analyzed to determine key parameters such as:

154 - Average daily energy consumption (kWh)

155 - Peak daily load (kW)

156 - Minimum daily load (kW)

157 - Distinct peak demand periods

158 This characterization provided insights into the facility's energy requirements and informed
159 the sizing and configuration of the integrated energy system components.

160

161 The interaction between the existing energy systems, storage systems, and the solar
162 inverter system was also simulated using the HOMER pro software to assess how they can
163 meet the facility's energy needs and optimize energy usage.

164 **2.3 System Modeling**

165 The studied health-care system was modeled by specifying the load profile of the facility,
166 designing the configurations and motives of the system, and assessing the energy supply
167 status and availability of the Solar PV systems. HOMER pro software was used to simulate
168 the electricity generation potential of the solar inverter hybrid system under observation
169 based on collected solar irradiance data and system specifications. For this study, three
170 configurations were focused on in the course of the modelling.

171 **2.4 Economic Analysis**

172 Economic tools and models were used to investigate the financial viability of this study.
173 Using the cost-benefit analysis (CBA) as a tool, the potential cost savings from reduced grid
174 dependence and fuel costs were compared to the initial investment. Ongoing maintenance
175 costs were also established. Carrying out a cost-benefit analysis involves a structured
176 process of identifying, measuring, and comparing the projected costs and benefits of a
177 project or intervention. The simulations were based over a period of twenty-five (25) years.

178 The procedure for economic analysis is as itemized below:

179 1. Defining the Project: This was defined as integration of solar PV systems into the existing
180 energy infrastructure of the healthcare facility.

181 2. Identification of Costs and Benefits:

182 *Costs:* A list of all anticipated costs associated with the project was made. This includes:

183 *Direct Costs:* These are tangible expenses directly linked to the project.

184 *Indirect Costs:* less obvious costs like infrastructure upgrades needed, or potential
185 productivity losses during implementation.

186 *Benefits:* The expected benefits of the intervention were identified.

187 3. Quantification of Costs and Benefits: Monetary value was assigned to both the costs and
188 benefits where necessary. This allowed for a more direct comparison.

189 It might be challenging to assign a monetary value to some benefits like improved quality of
190 life. In such cases, these limitations were acknowledged and qualitative descriptions were
191 employed alongside the quantitative data.

192 4. Establishment of a time frame: This is the timeframe over which costs and benefits are
193 being considered. This is important because benefits may accrue over time, while some
194 costs might be upfront. The simulation period was set at 25 years.

195 5. Cost-Benefit Analysis: This method became necessary in assigning a monetary value to
196 both costs and benefits. Likewise, net benefit (benefits minus costs) was calculated to
197 assess the overall economic viability of an intervention.

198 Other financial models were employed to perform calculations for: payback period, Internal
199 Rate of Return (IRR), Net Present Cost (NPC), and Levelized Cost of Energy (LCOE).

200 1. *Cost Benefit Analysis (CBA)* = $\frac{\sum \text{Present Value of Future Benefits}}{\sum \text{Present Value of Future Costs}}$ (1)

201

202 2. *Internal Rate of Return (IRR)* = $r_a + \frac{NPV_a}{(NPV_a - NPV_b)} (r_b - r_a)$ (2)

203

204 Where:

205 r_a = Lower discount rate chosen

206 r_b = Higher discount rate chosen

207 NPV_a = Net Present Value at r_a

208 NPV_b = Net Present Value at r_b

209

210 3. *Net Present Cost (NPC)* = $\sum_{n=1}^N \frac{C_n}{(1+r)^n}$ (3)

211

212 Where:

213 $N = \text{Total number of time periods}$

214 $n = \text{Time period}$

215 $C_n = \text{Net cash flow at time period}$

216 $r = \text{internal rate of return}$

217

218 4. *Levelized Cost Of Energy (LCOE)* =
$$\frac{\sum \frac{(I_t + M_t + F_t)}{(1+r)^t}}{\sum \frac{E_t}{(1+r)^t}} \dots\dots\dots(4)$$

219

220 Where:

221 $I_t = \text{The initial cost of investment expenditure in the year } t$

222 $M_t = \text{Maintenance and operations expenditures in the year } t$

223 $F_t = \text{Fuel expenditures in the year } t \text{ (If applicable)}$

224 $E_t = \text{The sum of all electricity generated in the year } t$

225 $r = \text{discount rate of the project}$

226 $n = \text{Life of the system}$

227

228 5. Payback Period

229 a. *Simple Payback Period* =
$$\frac{\text{Initial Investment or Original Cost of the Asset}}{\text{Cash Inflows}} (6)$$

230 b. *Discounted Payback Period* =
$$\frac{\text{Initial Investment}}{(\text{Discount Rate} \times \text{Annual Cash Flow})} (7)$$

231 **2.5 Limitations**

232 The study may be limited by the availability of secondary data regarding energy usage,
 233 and requirements for medical equipment. Also, considering variables like weather,
 234 shadowing, and system deterioration over time, the analysis might not adequately
 235 account for potential variations in energy generation from solar panels.
 236

237
238
239
240

3. RESULTS AND DISCUSSION

241 In this section is showcased the results obtained from appraising the economics of
242 integrating solar inverter into existing energy system at an Ikeja-based healthcare facility.

243 3.1 Setting



244 **Fig. 1. Map showing Ikeja, Lagos, Nigeria, the location of the healthcare facility**
245 **(Source: [35]).**
246 Ikeja, Lagos, Nigeria (Figure 1), which is the setting for this work, is located on geographical
247 coordinates 6.6018° N, 3.3515° E [36].
248

249 3.2 Data Collection


250 Having carried out all the procedures as described under section 2.2 (walk-through audit), it
251 was deduced that the healthcare facility installed both national electricity grid, with a 50 kV
252 generator serving as power backup. Table 2, which gives details on the average hourly
253 consumption of the facility for 24 hours, was obtained. From the information available in
254 Table 2 (and the appendix), the average daily consumption of the healthcare facility is found
255 to be 29.02 kW, while the total daily load (average) is 172.24 kW. The peak daily load is
256 12.33kW while the minimum daily load is 2.13kW. Also shown in Figure 2 is the hourly load
257 consumption trend.

258
259

Table 2. Load Profile of Facility

Hour	Load (kW)
0 – 1	2.13
1 – 2	2.15
2 – 3	2.33
3 – 4	2.21
4 – 5	2.41

5 – 6	3.16
6 -7	5.12
7 – 8	7.32
8 – 9	8.11
9 – 10	12.32
10 – 11	12.21
11 – 12	12.33
12 – 13	8.23
13 – 14	8.34
14 – 15	8.14
15 – 16	8.46
16 – 17	9.04
17 – 18	12.02
18 – 19	12.32
19 – 20	12.13
20 – 21	9.47
21 – 22	10.43
22 – 23	9.16
23 – 24	5.02



261
262


Fig. 2. Hourly Load Profile

263
264
265

This chart signifies an increase in load demand between 9am-12pm and 4pm-7pm, indicating that these are the periods the healthcare facility usually operates heavy equipment, thereby increasing the load demand.


266
267
268

Also obtained include the data (downloaded) detailing the Solar GHI and the temperature for every month of the year. Figure 3 shows the Solar GHI while Figure 4 shows the temperature distribution.



269
270

Fig. 3. Solar GHI for facility Location (Source: [37])



271
 272
 273

Fig. 4. Monthly average temperature data for facility location (Source: [29])

274 From Figure 4, it can be seen that the months of Feb, Mar, Apr, May, Nov and Dec have the
 275 highest radiation values, indicating that these are months wherein the Solar PV system can
 276 generate peak electricity. With August having the lowest radiation level, it means it is the
 277 month with the lowest solar energy potential. The Solar PV system model consists of a
 278 generic flat plate PV and 12V, 1kWh lead acid battery as storage.

279 The relevant technical specifications and cost information for the systems components, such
 280 as solar PV panels, batteries, converters, and diesel generators, collected through market
 281 research and secondary sources include: information on size, the cost of purchase,
 282 installation, operation, maintenance, and the useful life of the equipment. These are as
 283 presented in Table 3.

284 **Table 3. Cost of System components**


Equipment	Size	Capital Costs (\$)	Replacement Costs (\$)	O & M costs (\$)	Useful Life
Solar Panels	0.325 Kw	200	190	5.00	25 years
50 kVa Generator	50 kVa	0.00	3,000	1.50	15,000 hours
System Converter	10Kw	1,500	1,500	10	15 years

Battery	12v, 2.64kWh	200	200	2.00	18 years
---------	--------------	-----	-----	------	----------

285 The Base system already has a 50Kva generator as a backup source, bringing the capital
 286 cost of the generator to \$0.

287 **3.3 System Modelling**

288 The three major energy sources put into consideration for in the study include: 1) Grid
 289 electricity, 2) A 50kva backup generator currently in use at the facility and 3) The proposed
 290 Solar PV system (comprising of 10kW system DC – AC converter (inverter); 7 of 12V, 210
 291 Ah batteries; PVS series by BAE, Germany in block form; and 31 of 0.325kW each capacity
 292 generic flat plate PV panels). Figure 5 shows a schematic model of the system detailing the
 293 converter, batteries, PV system Generator, and load profile.



294


295 **Fig. 5. Schematic model of the system**

296

297 The healthcare facility under study currently relies solely on Grid electricity, and with a
 298 50Kva Generator as power backup. The facility combines these two sources to achieve a
 299 24-hour power supply. Altogether, the three configurations considered in this study include:
 300 1) Base configuration (GG – Grid electricity and Generator, currently in use in the healthcare
 301 center under consideration); 2) Test A configuration (SGG – Solar, Grid electricity and
 302 Generator) configuration; 3) Test B configuration (SG – Solar and Grid electricity).

303 **3.4 Economic Analysis**

304 **Base system:** With the existing energy system in the healthcare facility taken as the base
 305 configuration for the first simulation, over a period of 25 years, results, as shown in Figure 6
 306 were obtained. Table 4 also presents the details of the economic analysis of the system.
 307



308

309 **Fig. 6. Cost distribution for Base (GG) system over 25 years**

310 There was no capital cost incurred for the generator and grid, due to the fact that the system
 311 is already under usage. The diesel generator incurs majority of the costs as: replacement
 312 costs, operating and maintenance (O and M costs and high fueling cost. Over the length of
 313 the simulation (25 years), 27,447 liters of diesel fuel would have been consumed, bringing
 314 the total fueling cost to \$1,113,849.16 with an average daily consumption of 75.2L. This
 315 poses a major problem for the base system.

316 **Table 4. Net Present Cost of Base (GG) System**

Component	Capital (\$)	Replacement (\$)	O & M (\$)	Fuel(\$)	Salvage (\$)	Total (\$)
50 kVa Capacity Generator	0.00	37,908.91	324,013.67	1,113,849.16	472.39	1,475,299.35
Grid	0.00	0.00	187,858.76	0.00	0.00	187,858.76
System	0.00	37,908.91	511,872.43	1,113,849.16	472.39	1,663,158.11


317 **Solar-Grid (SG) system:** On simulating another (SG) system (Test B configuration), also
 318 over a period of 25 years, the system recorded a total NPC of \$422,558.31, with majority of
 319 the costs being associated to capital and operating costs, as shown in Figure 7. While this is
 320 significantly lower than the NPC of the base system, it also poses a challenge of high initial
 321 setup cost and partial reliance on unstable grid electricity without provision for a backup in a
 322 case of unmet electricity demand. Table 5 covers the economic analysis of the Solar-Grid
 323 system.

324 **Table 5. Net Present Cost of Solar-Grid (SG) System**

Component	Capital (\$)	Replacement (\$)	O & M (\$)	Fuel (\$)	Salvage (\$)	Total (\$)
BAE PVS Block 12V 210	72,400.0	134,429.79	29,177.35	0.00	104,503.85	131,503.29
Grid	0.00	0.00	95.13	0.00		95.13

Generic Flatplate PV	4	138,927.9	0.00	139,970.62	0.00	0.00	278,898.56
System Converter		5,593.92	9,368.73	1,502.91	0.00	4,404.22	12,061.34
System	6	216,921.8	143,798.51	170,746	0.00	108,908.0	422,558.13

325
326



327
328

Fig. 7. Cost distribution of Solar-Grid (SG) system over 25 years


329 This configuration (Test B) has an LCOE of \$0.1436 and a yearly operating cost of
330 \$5102.62, which are also lower than those of the base configuration. However, with an initial
331 capital of \$216,922, ROI 12.5% of and a discounted payback period of 5.28 years, this may
332 not be the most economical option for the healthcare facility.

333 **Solar-Grid-Gen. (SGG) system:** On simulating the Solar-Grid-Gen. (SGG) system (Test A)
334 configuration over a period of 25 years, results, as shown in Figure 8 were obtained. Table 6
335 also presents the details of the economic analysis of the system.

336 **Table 6. Net Present Cost of (SGG) System**

Component	Capital (\$)	Replacement (\$)	O & M (\$)	Fuel (\$)	Salvage (\$)	Total (\$)
BAE PVS Block 12V 210	50,400.0	87,062.93	20,311.30	0.00	50,912.09	106,862.14
50Kva Capacity Generator	0.00	0.00	5,682.33	19,312.11	5,975.77	19,018.66
Grid	0.00	0.00	856.77	0.00		856.77

Generic Flatplate	123,678.4	0.00	124,606.68	0.00	0.00	248,285.14
PV	5					
System Converter	3,358.13	5,624.21	902.22	0.00	2,643.93	7240.63
System	177,436.5	92,687.13	152,359.31	19,312.11	59,531.79	382,263.33
	8					



337
338

Fig. 8. Cost distribution of Solar-Grid-Generator (SGG) system over 25 years

339 The total NPC for the SGG system is \$382,263.33 with the majority of the costs incurred
340 from capital, operating and maintenance costs, as shown in Figure 8. The system also
341 generates \$59,531.79 in salvage costs. The SGG system can be said to be almost
342 independent of grid electricity with, a total purchase of 113 kWh/yr at a cost of \$856.77. This
343 is due to the system generating enough electricity to meet the maximum load demand of the
344 facility, which is 64,273 kWh/yr. The Solar PV system generates 88,046 kWh/yr. This brings
345 about an excess electricity of 12,112 kWh/yr. So far, it is the most economical option out of
346 the three configurations considered.

347 Having discussed the results of various simulation scenarios, a summary of the cost
348 analyses of both GG (base/highest-cost) and SGG (lowest-cost) systems are as shown in
349 Table 7.

350 **Table 7. Cost Comparison of the Base and Lowest-Cost Systems**


Summary	GG (Base) System	SGG (Lowest-Cost) System
Total NPC	\$1,663,158.11	\$382,263
Initial Capital	0.00	\$177,437
Operating Cost	\$41,269/yr.	\$5,083/yr.
Levelised COE	0.642/kWh	0.139/kWh

351 As shown in Table 7, while the GG system in use by the healthcare facility incurred an NPC
 352 of \$1,663,158.11, the SGG system generated a total NPC of \$382,263 over the simulation
 353 lifetime (25 years), realising a total savings of \$1,280,895.11. The system payback period is
 354 4.8 years, with an ROI of 16% and an IRR of 20%. Table 8 shows a summary of the
 355 economic metrics of the lowest-cost (SGG) system.

356 **Table 8. Economic Metrics**

Metric	Value
Present Worth (\$)	1,280,895
Annual Worth(\$)	31,784
Return on Investment (%)	16.2
Internal rate of return (%)	20.3
Simple Payback yr.	4.83
Discounted payback yr.	4.39

357
 358 The levelized cost of energy for the optimal system is \$0.1390 while the operating cost of the
 359 system is \$5,083/yr as against the base system where the levelized cost of energy is \$0.642
 360 with an operating cost of 41,269/yr. This shows that the integration of solar PV is a much
 361 more economically viable option for the healthcare facility on the long run. Figure 9 shows
 362 the graph of the cost savings of the SGG system against the base system over time.



363
364 **Fig. 9. Graph of cumulative nominal cash flow against time**

365 The lowest cost (SGG) system starts out as more expensive due to the high initial setup
366 capital required, but due to the low operating and maintenance costs, it is able to save a lot
367 of cost overtime that would have otherwise been incurred for fueling in the base system.

368 It is very important to note that while this might be the most cost-effective of all options, Initial
369 investment cost is a major barrier to the implementation of this system, as the facility under
370 observation is a medium-scale privately owned healthcare facility. Another possible
371 challenge in the implementation of the lowest-cost system is that of space constraint (for
372 panels and batteries installation).

373 **3.5 Qualitative Benefits of the SGG System: Practical Implications**

374 Some of the benefits of the SGG configuration cannot be quantified by cost as monetary
375 value cannot be attached to them. Some of these benefits are listed below;

376 **1. Increased Energy Security and Resilience:** By introducing a renewable energy source
377 like solar PV, the system becomes less dependent on the main grid. This reduces the risk of
378 outages caused by grid failures or disruptions. Even during partial outages, the PV system
379 can provide a sufficient level of power, keeping critical equipment operational.

380 **2. Reduced Dependence on Fossil Fuels:** A solar PV system generates clean energy,
381 decreasing the reliance on fossil fuel-based power plants. This translates to lower
382 greenhouse gas emissions and a smaller environmental footprint for the entire healthcare
383 system which is important, as Nigeria is one of the largest greenhouse gas producers in
384 West Africa.

385 **3. Improved Quality of Healthcare:** A stable and reliable electricity supply is crucial for
386 maintaining critical medical equipment and ensuring uninterrupted patient care. Even though
387 the base system also ensures 24-hour electricity supply, the frequent interruptions, and
388 changeovers were a major problem to equipment for life support, diagnostic tools, and
389 temperature-controlled storage for medications and vaccines. Consistent power also
390 improves the overall environment for both patients and staff, enhancing the quality of care
391 provided.

392 **4. Potential for Lower Energy Costs:** HOMER simulations have considered the cost of
393 both grid electricity and the PV system over the simulation lifetime of 25 years. The analysis
394 showed stable electricity with the hybrid configuration, this suggests a significant potential for
395 long-term cost savings. The PV system also offsets a large portion of the electricity needs,
396 greatly reducing reliance on potentially expensive grid power.

397 **5. Potential for Increased Property Value:** An integrated renewable energy system can
398 make a property appear more appealing and eco-friendly. This might result in higher
399 property values, particularly for structures like hospitals where energy efficiency is becoming
400 more and more crucial.

401

402

403

404

405

4. CONCLUSION

406

407

408

409

410

411

412

413

414

415

In this study, the economic analysis of integrating a solar photovoltaic (PV) system into the existing energy infrastructure in a healthcare facility in Nigeria has been appraised. Findings showed the optimal system configuration to be the Solar-Grid-Generator (SGG) system, comprising of solar PV panels, lead-acid batteries, a system converter, alongside existing national grid and diesel generator. This hybrid system has a significantly lower net present cost (NPC) of \$382,263, compared to the base case scenario of \$1,663,158, which relies totally on grid electricity and the diesel generator. The levelized cost of energy (LCOE) for the hybrid system is \$0.139/kWh, which is also much lower than the base case LCOE of \$0.642/kWh.

416

417

418

419

Also, integrating solar PV systems with existing energy infrastructure in a healthcare facility, considering the facility's load profile and energy demand patterns, solar resource potential, and the requirement for power backup from diesel generator was successfully modeled and simulated.

420

421

422

423

424

425

426

Beyond economic benefits, the Solar-Grid-Generator (SGG) system also offers qualitative benefits that cannot be quantified by cost. It increases energy security and resilience by eliminating reliance on the main grid and diesel generators. The integration of a solar PV system which is a renewable energy source also contributes to a lower environmental footprint and reduced greenhouse gas emissions. The stable and reliable electricity supply facilitated by this system can improve the quality of healthcare services provided at the facility.

427 Finally, this study successfully demonstrated that integrating a solar PV system with the
428 existing energy infrastructure at the healthcare facility in is not only economically feasible,
429 but additionally offers significant long-term cost savings, as well as contributing to
430 environmental sustainability and improved healthcare services. However, the implementation
431 of such a system may face challenges of initial high investment costs and space availability
432 for the installation of solar panels and batteries. Implementing solar integration projects can
433 only be easy with access to financial support mechanisms and or, intervention from
434 government. By offering tax breaks, grants, or facilitating access to low-interest loans
435 specifically for solar projects, governments can significantly improve the financial
436 attractiveness of solar power for healthcare facilities. These incentives will not only
437 encourage wider adoption, but will also contribute to achieving the national renewable
438 energy goals.

439
440

441 **ACKNOWLEDGEMENTS**

442
443
444
445
446
447
448

We sincerely express our gratitude to the management of the Ikeja, Lagos, Nigeria based private hospital selected for this research. Your support and cooperation contributed so much to the success of the work.

449
450

449 **COMPETING INTERESTS**

451
452

"Authors have declared that no competing interests exist."

453
454

453 **AUTHORS' CONTRIBUTIONS**

455
456
457
458
459

"Author 1' designed the study, wrote the protocol, and wrote the final draft of the manuscript. Author 1' is also responsible for the APC. Author 2' performed the analyses and wrote the first draft of the manuscript. 'Authors 1' and 2' both managed the literature searches. Both authors read and approved the final manuscript."

460
461

460 **REFERENCES**

462

[1] Oyedepo, S.O., 2014. Towards achieving energy for sustainable development in Nigeria. *Renewable and Sustainable Energy Reviews* 34:255-272.

463
464
465
466

[2] Afolabi, D. D., Adeyemo, A. A. and Odumosu, A. A. 2018. Economic Analysis of Renewable Energy Sources for Power Generation in Hospitals within Ibadan Metropolis, Nigeria. *International Journal of Scientific & Engineering Research* 9.8:1872-1881.

467
468
469

[3] Ikeako, L. C., Okoli, B. E. and Nwagha, U. G. 2018. The effects of health worker strikes on access to healthcare services in developing countries: The case of Nigeria. *International Journal of Nursing Studies* 87: 102-110.

470
471
472

[4] Uche, I. M., Okafor, C. N. and Onwurah, I. O. 2019. Challenges of communication in the Nigerian healthcare system. *International Journal of Research in Pharmacy and Science* 9.6:1822-1828.

- 473 [5] Ojo, T., Adebayo, O. M. and Onifade, T. M. 2020. Improving access, quality and
474 efficiency in health care delivery in Nigeria: a perspective. *Pan African Medical*
475 *Journal*. 36.208.
- 476 [6] Onoh, C. H., and Igwono, O. U. 2021. Powering Rural Healthcare Facilities with
477 Renewable Energy in Nigeria: A Review of Challenges and Opportunities.
478 *International Journal of Renewable Energy Research*, 11(4), 381-388.
- 479 [7] International Renewable Energy Agency (IRENA). (2019). Renewable Energy
480 Market Analysis: The Case of Nigeria.
- 481 [8] Sambo, A. S., and Sanda, M. N. 2016. Solar Energy Resource Assessment and
482 Potential in Nigeria.
483 https://www.researchgate.net/publication/285704500_Solar_energy_potentials_in_strategically_located_cities_in_Nigeria_Review_resource_assessment_and_PV_system_design.
484
485
- 486 [9] Nwadei, O., and Oladipo, E. O. 2017. Challenges and policy options for
487 deploying renewable energy in Nigeria. World Economic Forum.
488 <https://www.weforum.org/agenda/2023/05/how-nigeria-is-tackling-barriers-to-its-green-energy-transition/>
489
- 490 [10] Akinola, A. A. 2023. Solar photovoltaics development in Nigeria: Drivers,
491 barriers, and policies. *Energy and Power Engineering*, 15(3), 315-328.
- 492 [11] Khatib, T., 2019. Photovoltaic Systems and the National Electrical Code:
493 Suggested Practices. Photovoltaic Systems and the National Electrical Code:
494 Suggested Practices.
- 495 [12] Faias, S., Ferreira, P. and Teixeira, F., 2020. Bi-directional single-phase battery
496 charger for solar photovoltaic powered electric vehicle charging station in buildings.
497 *Electric Power Systems Research*, 185.106357.
- 498 [13] Forsberg, C., Petit, E.J., Beckman, J.P. and Rathbun, H., 2021. Shades of
499 green: Spatial, manufacturing, and life cycle environmental impacts of regionally-
500 adapted light-weight green roofs. *Renewable and Sustainable Energy Reviews*
501 152.111833.
- 502 [14] Wang, B., Canha, L.N., Alhindawi, N. and Tabors, R., 2018. The impacts of
503 resource integration and transmission constraints on energy system economics and
504 renewable energy resources. *Applied Energy* 226:357-368.
- 505 [15] Blaabjerg, F. and Teodorescu, R., 2013. Inverters for photovoltaic systems - an
506 overview. In *Photovoltaic Energy Conversion: The State of the Art of Inverters,*
507 *Power Conditioning and MPPT* (pp. 508-562). Noida: Alpha Science International
508 Ltd.
- 509 [16] Kourovskaya, P. R., Boggarov, S. C., Hinov, N. L., and Rangelova, V. M. 2014.
510 Grid connected photovoltaic systems. *Technical Gazette* 21.2:293-299.
- 511 [17] Zhao, H., Wang, Z., Xu, W., and Sun, Y. 2022. A Review of Hybrid Inverters for
512 Solar Energy Storage Systems. In *2022 IEEE 5th International Conference on*

- 513 Automation, Cognitive Science and Information Processing (ACSIP) (pp. 1-6). IEEE.
514 <https://ieeexplore.ieee.org/document/9795622/>
- 515 [18] Bolarinwa, M. A. 2018. Techno-economic evaluation of biogas generation from
516 selected substrates in a teaching and research farm in Ibadan, Oyo State, Nigeria.
517 *International Journal of Innovative Science and Research Technology*. Vol.3. Issue
518 7: 699-704.
- 519 [19] National Bureau of Statistics (NBS). 2022. Nigerian Electricity Report.
- 520 [20] Bolarinwa, M. A., Adeyemi, A. A., and Kassim, O. E. (2023). Technoeconomic
521 analysis of prototype hydropower plant development in Nigeria. *European Journal of*
522 *Engineering and Technology Research*, 8(3), 29–37.
523 <https://doi.org/10.24018/ejeng.2023.8.3.2972>
- 524 [21] Akorede, M.F., Ibrahim, O., Amuda, S.A., Otuoze, A.O. and Olufeagba, B.J.,
525 2018. Current status and outlook of renewable energy development in Nigeria.
526 *Nigerian Journal of Technology* 36.1:196-212.
- 527 [22] Bolarinwa, M. A. 2020. The role of renewable energy in Nigeria's energy
528 transformation: Advancing industrial engineering in Nigeria through teaching,
529 research and innovation. Edited by Ayodeji E. Oluleye; Victor O. Oladokun and
530 Olusegun G. Akanbi. A book of reading. Chapter 7. Pp 171-194. Leading Edge
531 Printers and Publisher, Ibadan.
- 532 [23] Chatterjee, A., Isufaj, A., Ali, M., Lanka, E., Yan, D., Hegedus, L. and Hossain,
533 J.A., 2019. Use of solar photovoltaic power for sustainable healthcare facilities: A
534 case study on health facilities in the Indian Himalayan region of Uttarakhand.
535 *Journal of Cleaner Production* 228:1512-1521.
- 536 [24] Luo, X., Wang, J., Li, Z., Lei, Z., and Li, J. 2021. Economic viability analysis of
537 energy storage integration in power systems: A review. *International Journal of*
538 *Electrical Power & Energy Systems*, 130, 106922.
539 <https://www.sciencedirect.com/science/article/abs/pii/B978012821602600016X>
- 540 [25] Tran, Q. N. 2020. Cost-Effectiveness of Grid-Connected Energy Storage
541 Systems for Peak Demand Reduction: *A Review on Sustainability* 12.24:10533.
- 542 [26] Ogbu, M. O., Baruah, D. C., Achumba, I. B. and Egbe, C. U. 2017. Economic
543 analysis of grid-connected solar pv systems for residential buildings in Uyo, Nigeria.
544 *International Journal of Renewable Energy Research (IJRER)* 7.2:567-578.
- 545 [27] Zhang, X. 2019. Economic Analysis of Residential Energy Storage Systems: A
546 Review. *IEEE Access*, 7:62549-62567.
- 547 [28] Aliyu, S. M., Bala, M. J., Ibrahim, M. N., and Syafe'i, N. N. 2018. Economic
548 viability of solar PV systems in different climatic zones of Nigeria. *Renewable*
549 *Energy*, 121, 432-445.
- 550 [29] Okoye, C. O., and Solyali, M. 2017. Techno-economic and policy appraisal of
551 solar PV integration in Nigeria. *Renewable and Sustainable Energy Reviews*, 78,
552 1136-1152.

553 [30] Hassan, Q., Algburi, S., Sameen, Z. Salman, H. M., and Jaszczur, M. 2023. A
554 review of hybrid renewable energy systems: Solar and wind-powered solutions:
555 Challenges, opportunities, and policy implications. *Results in Engineering*. Volume
556 20. Elsevier. <https://doi.org/10.1016/j.rineng.2023.101621>.

557 [31] Gupta, S., Gupta, P., Matapurkar, P. and Rajput, V. 2023. Integration of solar
558 and wind energy: A review of challenges and benefits. *Journal of Emerging
559 Technologies and Innovative Research*. Volume 10, Issue 3. <https://www.jetir.org>.

560 [32] Purwanto, P., Hermawan, and Suherman. 2019. Integration of Solar Energy
561 Supply on the Smart Home Micro Grid to Support Efficient Electricity and Green
562 Environment. *IOP Conf. Ser.: Earth Environ. Sci.* 239012032.
563 <https://doi:10.1088/1755-1315/239/1/012032>.

564 [33] Padmanathan, K, Govindarajan, U., Ramachandaramurthy, V. K., Selvi, T.,
565 Jeevarathinam, B. 2018. Integrating solar photovoltaic energy conversion systems
566 into industrial and commercial electrical energy utilization—A survey. *Journal of
567 Industrial Information Integration*. Volume 10. Pp 39-54.
568 <https://doi.org/10.1016/j.jii.2018.01.003>.

569 [34] Bolarinwa, M. A., and Abodunde, P. A. 2023. Energy waste reduction in
570 university of Ibadan, Nigeria’s water factory using energy audit approach. *European
571 Journal of Engineering and Technology Research* 8 (5), 1-11.

572 [35] Map data. 2024. Google Nigeria.
573 [https://www.google.com/maps/place/Ikeja,+Lagos/data=!4m2!3m1!1s0x103b922fa2
574 a39990xd7a8324bddbba1f0?sa=X&ved=1t:2428.;ctx=111](https://www.google.com/maps/place/Ikeja,+Lagos/data=!4m2!3m1!1s0x103b922fa2a39990xd7a8324bddbba1f0?sa=X&ved=1t:2428.;ctx=111)

575 [36] Maptons. 2024. Ikeja on the map of Nigeria. <https://ng.maptons.com/2892711>

576 [37] National Renewable Energy Laboratory (NREL) Database. 2024. Energy
577 efficiency and renewable energy. Alliance for sustainable energy, LLC. U.S.
578 Department of Energy. [https://www.nrel.gov/comm-standards/editorial/references-
579 and-citations.html](https://www.nrel.gov/comm-standards/editorial/references-and-citations.html)

580
581
582
583

APPENDIX

584
585

S/N	Hospital Equipment	Peak Power Usage	Minimum Power Usage	Duration of Usage (hrs)		
1	Lightnings	3.24	1.24	24		
2	Fans	3.46	1.33	24		
3	A.C	5.68	2.77	24		

WEEKENDS Load Profile

Time	0_6	6_12	12_18	18_24
JAN	14.33	16.78	26.78	36.11
FEB	10.22	12.98	19.75	35.09
MAR	12.56	16.34	18.67	37.22
APR	11.33	25.57	20.22	33.99
MAY	15.34	17.32	38.21	33.99
JUN	16.43	12.27	34.56	35
JUL	17.57	12.45	34.97	36.63
AUG	12.34	13.54	35.66	36.05
SEPT	13.34	10.45	23.76	35.34
NOV	28.45	13.43	21.88	36.12
DEC	15.67	11.44	22.87	37.43

Weather Data:

Month	Average Temperature (oC)	Average Humidity (%)
January	25.9	65
February	26.94	60
March	27.22	55
April	26.99	50
May	26.35	45
June	25.5	40
July	24.65	45
August	24.41	50
September	24.92	55
October	25.55	60
November	26.2	70
December	26.01	70

Fixture Type	Number of Fixture	Wattage	Operating Schedule
Fluorescent	120	28W	6 AM - 8 PM daily
LED	60	15W	24/7

Building Size (Sq. ft.)	Number of Floors	Building Age (Years)	Construction Materials	Window Types
26,800	2	21	Concrete, Steel, Brick	Double-paned

WEEKDAYS Load Profile

Time	0_3	6_9	9_12	12_1	15_18	18_21	21_24
------	-----	-----	------	------	-------	-------	-------

	3_6		5					
JAN	6.043	7.34	19.44	36.34	24.25	26.03	29.33	39.45
FEB	4.643	7.13	19.75	36.11	24.87	25.43	35.34	30.22
MAR	5.46	6.88	18.67	35.09	24.65	24.67	38.21	32
APR	6.222	6.78	20.22	37.22	21.28	25.54	34.56	31.33
MAY	7.03	7.11	20.33	33.99	23.76	24.44	34.97	32.45
JUN	6.98	7.28	19.75	35	22.97	27.87	35.66	34.56
JUL	5.77	6.88	19.55	36.63	24.64	25.77	35.56	33.14
AUG	6.043	6.86	19.47	36.05	24.25	25.23	35.33	30.45
SEPT	4.65	7	20.66	35.34	23.76	25.99	34.65	33.24
NOV	5.87	7.24	19.75	36.12	21.88	24.86	33.45	30.22
DEC	6.44	6.98	19.85	37.43	22.87	23.98	35.34	30.44

Occupant Type	Number	Occupancy Schedule
Patients	30	24/7
Staff (Doctors/Nurses)	35	7 AM - 7 PM (Weekdays)
Staff (Administrative)	15	8 AM - 5 PM (Weekdays)
Visitors(Avrg)	30	10AM-8PM(DLy.)