

Original Research Article

Enhancement of the Small-Signal Stability of Nigerian 330 kV Transmission Network using Static Synchronous Compensator

ABSTRACT

Aims: To analyze the small-signal stability of the Nigerian 330 kV transmission system and the performance of Static Synchronous Compensator (STATCOM) controller in enhancing the system's stability upon incorporation

Study design: Data collection from Transmission Company of Nigeria (TCN) national control centre.

Place and Duration of Study: Department of Electronic and Electrical Engineering, Faculty of Engineering and Technology, Ladake Akintola University of Technology (LAUTECH), Ogbomoso, Oyo State, Nigeria. October 2023 to December 2024

Methodology: Newton-Raphson method of solution was adopted for the power flow analysis and Eigenvalues method was employed for small-signal stability analysis. Simulation was used for the analysis and was carried out on Power System Analysis Toolbox (PSAT) software version 2.1.11 in MATLAB environment.

Results: The voltage magnitudes from power flow results of Nigerian transmission network for five critical buses, buses Damatguru, Gombe, Jalingo, Maiduguri and Yola gave 0.8529, 0.8529, 0.8299, 0.8249 and 0.83433 p.u respectively. While the corresponding magnitudes after incorporating STATCOM controller were 1.02, 0.9768, 0.9568, 1.05, 0.9607 p.u. Furthermore, the eigenvalues result for small-signal stability contains seven positive eigenvalues. After incorporating STATCOM controller, all eigenvalues were negative.

Conclusion: The Nigerian transmission network is weak with voltage limits violation but the incorporation of STATCOM was able to bring the voltage magnitudes of all buses within limits. Also, the network is small-signal unstable, however, STATCOM controller was able to enhance the stability when incorporated.

Keywords: Small-Signal Stability, STATCOM, Eigenvalues, PSAT.

1. INTRODUCTION

The growing population has resulted into drastic increase in demand for electricity. In order to meet up with the demand of electricity, transmission network is being overloaded and push closer to their stability limit (Okolo *et al.*, 2020). The Nigerian transmission network controlled by Transmission Company of Nigeria (TCN), is faced with many challenges affecting its stability and reliability.

In Nigeria, the transmission network is essential in transmitting electrical energy from power generation stations to distribution networks and electrical power users. The Nigerian

transmission network, operated by Transmission Company of Nigerian (TCN), is often strained beyond its design capacity, leading to potential overloading and instability problem. Nigerian power grid is affected by a lot of problem which include, old, insufficient power grid equipment, insufficient generation and poor loadability. The 54-bus, 330 kV is comprises of 18 generators and 67 transmission lines. (Anyanor *et al.*, 2020). The gross installed generation capacity is about 13,300 MW, however, only 5900 MW net capacity has been available. The actual daily generation rarely reaches 4000 MW which is due to several outages, which maybe maintenance-based or forced outages. Also the power supply deficit necessitates load shedding which involves rationing of available power dispatch to meet only a portion of the total load demand (Adetokun and Muriithi, 2021).

Many system separations and blackouts has occurred in the history of power system industry as a result of oscillations generated from small disturbances (Hamarash, 2012).

Small-signal stability is the ability of power system to maintain synchronism under small disturbances such as small load variations and generations (Mondal *et al.*, 2020). It is associated with small disturbances generated from continuous switching on and off of small loads (Gibbard *et al.*, 2015). These small disturbances generate oscillations in power systems which, if not dampened out, can grow large, and result to instability and even blackout.

Several methods and approaches have been used by researchers in the analysis of small-signal stability of power systems such as, model-based analysis, measurement-based, and Eigenvalue analysis (Lin, 2015).

To dampen out the oscillations generated as a result of small disturbances, controllers such as PSS, AVR and FACTS controllers are already in use.

The first proposed method for introducing damping torque is the conventional power system stabilizer and the second method is Heffron-Philip's power system stabilizer (Doradla *et al.*, 2011).

Karthikeyan and Dhal (2015) worked on the enhancement of small-signal stability of IEEE-9 bus system via optimal placement of STATCOM controller. Eigenvalue method of analyzing small-signal stability was adopted.

Ogunjuyigbe and Gonoh (2022) examined the small-signal stability of 330 kV Nigerian network when subjected to small disturbances while adopting AVR for stability enhancement. Modal analysis method was employed to carry out the analysis.

FACTS controllers are technology which are capable of controlling one or more system parameters in order to improve controllability and power transfer capacity of the system (Mondal *et al.*, 2020).

STATCOM controller is a FACTS controller that has been widely used for enhancing voltage profiles of transmission systems, reducing active power losses in transmission lines and enhancing small-signal stability of power systems.

Adepoju *et al.* (2011) examined the power flow analysis of Nigerian transmission system with the incorporation of FACTS controllers. Three controllers were considered for the study; Static Synchronous Compensator (STATCOM), High Voltage Direct Current – Voltage Sourced Converter (HVDC-VSC) and Unified Power Flow Controller (UPFC), for voltage magnitude control, active and reactive power control.

Ambafi *et al.* (2012) investigated the performances of Power System Stabilizer (PSS) and Static Synchronous Compensator (STATCOM) controller in damping oscillations in power system when considered separately.

Aborisade *et al.* (2014) compared the voltage enhancement and loss reduction capabilities of STATCOM and SSSC controllers to address the problems of voltage instability, active and reactive power losses.

Jokojeje *et al.* (2015) investigated the effects of the application of STATCOM controller on the Nigerian transmission system performance using voltage magnitude and power profile as performance metrics.

Kumar and Kumar (2019) scrutinizes the effects of multiple combinations of Static Var Compensator (SVC) and STATCOM on load congestion mitigation of IEEE 14-bus system applying Weight Least Square (WLS) technique.

Incorporation of FACTS controllers into power system has shown enhancement in system stability. Many countries like China, Brazil, Canada, India and Saudi Arabia have installed FACTS controllers into their networks to support power transmission capabilities and grid stability Asad (2022).

2. MATERIAL AND METHODS

2.1 Small-Signal Stability of Power System Using Eigenvalue Analysis

PSAT uses a set of differential-algebraic equations (DAE) which is represented in the form:

$$\begin{aligned}\dot{x} &= f(x, y) \\ 0 &= g(x, y)\end{aligned}$$

Where x is the vector of the state variables, y the vector of algebraic variable, f vector of differential equations, and g is vector of algebraic equation (Milano, 2008). State matrix is computed by manipulating the Jacobian matrix and eigenvalues are calculated from the state matrix (Milano, 2008).

2.2 Research System Materials

The small-signal stability of the Nigerian 54-bus 330 kV transmission network was conducted. Figure 1 shows the one-line diagram of the network. The simulation of the transmission network was carried out using PSAT 2.1.11 in MATLAB environment. The procedures below were followed and STATCOM controller was connected to the weakest bus with the lowest voltage profile. The simulation results were presented.

2.3 Approach for conducting small-signal stability

Modelling of the transmission network by careful selection of suitable and appropriate models of synchronous machine, Automatic Voltage Regulator (AVR), Turbine Governor (TG) and STATCOM controllers. Preparation of the selected models on PSAT. Newton-Raphson power flow methods was adopted for power flow solution. These procedures were followed to compute eigenvalues of the system and determine the system's stability. The procedure for small-signal stability analysis is as follows:




Figure 3: Nigerian Transmission Network Eigenvalues Plot

STATCOM controller was connected to Maiduguri bus, the weakest bus with the lowest voltage magnitude. The power flow results for without and with incorporation of STATCOM controller are presented in table 1.

Figure 4 shows the voltage magnitudes of each buses with and without STATCOM controller's incorporation. The result shows that the voltages of the buses with voltage limit violation has improved and has been brought within limit implying that the controller has injected reactive power into the network to compensate for the losses.

The eigenvalue analysis was also carried out after the incorporation of the controller. Figures 5 shows the plot of imaginary parts against the real parts of the eigenvalues after the controller's incorporation. The positive eigenvalues has changed from 7 to 0. Hence, the system has become small-signal stable after incorporating STATCOM controller.

Table 1: Power Flow Results of Nigerian Transmission System without and with STATCOM

Bus Num	Bus Name	V [p.u]	Phase [rad]	V [p.u] (STATCOM)	Phase [rad] (STATCOM)	$P_{(gen)}$ [p.u]	$Q_{(gen)}$ [p.u]	$P_{(load)}$ [p.u]	$Q_{(load)}$ [p.u]
1	AES	1	0.0766	1	0.0766	2.452	-1.2769	0	0

2	Afam	1	-0.60379	1	-0.60304	7.2	3.8245	5.34	4.01
3	Aja	1.0264	-0.00671	1.0264	-0.00671	0	0	1.15	0.86
4	Ajaokuta	0.9838 9	-0.4617	0.9838 9	-0.46091	0	0	1.2	0.9
5	Akangba	0.9722 3	-0.10125	0.9722	-0.10118	0	0	2.03	1.52
6	Aladja	0.9881 3	-0.26642	0.9881 3	-0.26618	0	0	2.1	1.58
7	Alagbon	1.0237	-0.00955	1.0237	-0.00955	0	0	1.2	0.9
8	Alaoji	1	-0.6039	1	-0.60315	2.5	3.6042	4.67	2.7
9	Aliade	1.0119	-0.75728	1.0388	-0.75555	0	0	0.95	0.56
10	Ayede	0.9559 9	-0.15938	0.956	-0.15921	0	0	1.74	1.31
11	Benin	0.9877 4	-0.27207	0.9878 2	-0.27183	0	0	1.44	1.08
12	Benin-North	0.9771 4	-0.30441	0.9772 1	-0.30414	0	0	0.8	0.6
13	Birin-Kebbi	0.9688 5	-0.32586	0.9688 5	-0.32535	0	0	1.52	1.22
14	Calabar	1	-0.56143	1	-0.56059	6.18	-1.6496	0	0
15	Damaturu	0.8312 3	-0.89005	1.02	-0.88485	0	0	0.24	0.18
16	Delta	1	-0.25154	1	-0.25129	3.41	1.8601	0	0
17	Egbema	1	-0.57805	1	-0.57736	2.5	0.8502 6	0	0
18	Egbin	1.033	0	1.033	0	3.374 5	1.8378	0	0
19	Erukan	1.0031	-0.04787	1.0031	-0.04784	0	0	1.2	0.9
20	Eyaen	0.9739 7	-0.30921	0.9740 3	-0.30894	0	0	4.4	2.2

21	Ganmo	0.9786	-0.28828	0.9786 1	-0.28783	0	0	1	0.75
22	Geregu GS	0.985	-0.46103	0.985	-0.46024	4.85	5.3888	2	1.5
23	Gombe	0.8529	-0.86305	0.9767 5	-0.85664	0	0	0.68	0.51
24	Gwagwalada	0.9531 2	-0.63606	0.9531 5	-0.63485	0	0	2.2	1.65
25	Ihovbor	1	-0.26465	1	-0.26439	1.166	1.8212	0	0
26	Ikeja-west	0.9809 5	-0.09217	0.9809 5	-0.0921	0	0	8.47	6.35
27	Ikot-Abasi	0.9802 5	-0.62612	0.9810 4	-0.62544	0	0	2.27	1.7
28	Ikot-Ekpena	0.9997 7	-0.60578	1.0005	-0.60513	0	0	1.4	0.5
29	Jalingo	0.8298 7	-0.89122	0.9568 4	-0.87798	0	0	0.2	0.15
30	Jebba GS	1	-0.29759	1	-0.29706	4.03	4.6967	0	0
31	Jebba TS	0.9942 2	-0.30138	0.9942 3	-0.30087	0	0	2.6	1.95
32	Jos	0.9249 6	-0.78518	0.9755 8	-0.78393	0	0	0.72	0.54
33	Kaduna	0.9393 3	-0.737	0.9600 9	-0.736	0	0	1.43	0.98
34	Kainji	1	-0.29565	1	-0.29514	2.92	2.3488	0.89	0.67
35	Kano	0.9063 9	-0.7734	0.9279 4	-0.77078	0	0	1.94	1.46
36	Katampe	0.9419 6	-0.68275	0.9419 8	-0.68145	0	0	3.03	2.27
37	Lekki	1.0237	-0.00949	1.0237	-0.00949	0	0	1.15	0.86
38	Lokoja	0.9697 2	-0.50391	0.9697 4	-0.50303	0	0	1.2	0.9

39	Maiduguri	0.8248 8	0.89936	1.05	-0.89469	0	0	0.31	0.2
40	Makurdi	0.9933 3	-0.77104	1.0241	-0.77104	0	0	1.85	0.65
41	New Haven	1.0984	-0.69214	1.0990	-0.69161	0	0	1.96	1.47
42	New Haven South	1.0981	-0.69234	1.0990	-0.69181	0	0	1.75	1.31
43	Okpai	1	-0.52842	1	-0.52789	4.66	0.9245 3	0	0
44	Omoku	1	-0.57764	1	-0.57695	0.448	0.1824 1	0.3	0.2
45	Omosho	1.0006	-0.20101	1.0006	-0.20084	1.655	3.1355	1.2	0.58
46	Onitsha	0.9881 5	-0.56551	0.9898	-0.56514	0	0	5.13	3.7
47	Oshogbo	0.9734 2	-0.26372	0.9734 3	-0.26334	0	0	1.27	0.95
48	Owerri	0.9969	-0.58503	0.9970 6	-0.58435	0	0	1.8	0.75
49	Papalanto	0.973	-0.09328	0.973	-0.09319	2.04	-0.1842	0.71	0.58
50	Port Harcourt	1	-0.61381	1	-0.61305	1.78	1.7618	3.16	1.58
51	Sakete	0.9485	-0.13814	0.9485	-0.13807	0	0	2.05	1.11
52	Sapele	1	-0.25932	1	-0.25908	3.45	2.8576	1	0.77
53	Shiroro	1	-0.65792	1	-0.65652	3	9.7053	1.7	0.98
54	Yola	0.8343 3	-0.88556	0.9607 1	-0.87371	0	0	0.26	0.3




Figure 4: Voltage Profiles of Nigerian Transmission System without and with STATCOM Controller




Figure 5: Nigerian Transmission Network with STATCOM Controller Eigenvalues Plot

4. CONCLUSION

The power flow and small-signal stability analyses of the Nigerian transmission system has been carried out. The power flow results of the simulation revealed that the network is weak with voltage limit violation which confirmed the work of previous researchers (Adepoju *et. al.*, 2011). The incorporation of STATCOM was able to bring the voltages within limit. The eigenvalues results revealed that the network is small-signal unstable confirming (Ogunjuyigbe and Gonoh, 2022). The enhancement of the system's stability was achieved using STATCOM controller. Therefore, STATCOM controller enhanced the small-signal stability of Nigerian transmission network.

REFERENCES

1. Okolo, C. C., Ezechukwu, O. A., Enemu, F. O., Anazia, A. E., and Onuegbu, J. O. (2020). Improving Transient Stability of the Nigerian 330kv Transmission System on Ajaokuta—Benin Transmission Line with the Help of Artificial Neural Network (ANN) Based VSC High Voltage Direct Current Method. *International Journal of Advanced Engineering, Management and Science*, **6**(2), 95–104. <https://doi.org/10.22161/ijaems.62.5>
2. Anyanor, K.I., Atuchukwu, A.J., Okonkwo, I.I., (2020). Enhancing the Voltage Profile of 330 KV Nigerian Transmission Network Systems. *International Research Journal of Modernization in Engineering Technology and Science*, **2**(12), 1099-1115.
3. Adetokun, B. B., and Muriithi, C. M. (2021). Impact of Integrating Large-Scale DFIG-Based Wind Energy Conversion System on the Voltage Stability of Weak National Grids: A Case Study of the Nigerian Power Grid. *Energy Reports*, **7**(4), 654-666.
4. Hamarash, I. (2012). Small Signal Stability Analysis of Kurdistan Regional Power System. *Zanco Journal of Pure and Applied Science*, **1**(24), 1-16
5. Mondal, D., Chakrabarti, A., and Sengupta, A. (2020). Power system small signal stability analysis and control (2nd edition). Academic Press, United Kingdom.
6. Gibbard, M. and P., Pouyan and Vowles, David. (2015). Small-Signal Stability, Control and Dynamic Performance of Power Systems. The University of Adelaide Press, Adelaide.
7. Lin, D. (2015). Methods for Analyzing Power System Small Signal Stability, Ph.D Thesis, Memorial University of Newfoundland, Canada.
8. Doradla, P. H. K., Emandi, R., Venkatesh, B. N. S. P., and Sudheer, G. S. (2011). Design of Power System Stabilizer to Improve Small Signal Stability by Using Modified Heffron-Phillip's Model. *International Journal of Engineering Science and Technology*, **3**(6), 4888-4896.

9. Karthikeyan, K., and Dhal, P. (2015). Small Signal Stability Enhancement Using STATCOM Based on Eigen value analysis. *Indian Journal of Science and Technology*, **8**(34), 1-7.
10. Ogunjuyigbe J. K, and Gonoh B. A. (2022). Small Signal Stability Analysis of a 330KV Network: A Case Study of the Nigerian 330 kV Network. *Academy Journal of Science and Engineering*, **7**(1), 18–28
11. Adepoju, G. A., Komolafe, O. A., and Aborisade, D. O. (2011). Power Flow Analysis of the Nigerian Transmission System Incorporating FACTS Controllers. *International Journal of Applied Science and Technology*, **1**(5), 186-200.
12. Ambafi, J., Nwohu, M., Ohize, H., and Tola, O. (2012). Performance Evaluation of PSS and STATCOM on Oscillation Damping of a North-Central Power Network of Nigeria Grid System. *International Journal of Engineering*, **2**(2), 209-216.
13. Aborisade, D. O., Adebayo, I. G., and Oyesina, K. A. (2014). A Comparison of the Voltage Enhancement and Loss Reduction Capabilities of STATCOM and SSSC FACTS Controllers. *American Journal of Engineering Research*, **3**(1), 96-105.
14. Jokojeje, R. A., Adejumobi, I. A., Mustapha, A. O., and Adebisi, O. I. (2015). Application of Static Synchronous Compensator (STATCOM) in Improving Power System Performance: A Case Study of the Nigeria 330 kV Electricity Grid. *Nigerian Journal of Technology*, **34**(3), 564-572.
15. Kumar, J., and Kumar, N. (2019). Application of FACTS Devices for Congestion Mitigation in Power System. *International Journal of Management Technology and Engineering (IJMTE)*, **9**(2) 1588-1601.
16. Asad, T. (2022). Global FACTS Market Outlook: From STATCOM to Series Compensation. *PTR Incorporation*, 2-4.
17. Milano, F., (2008), *Power System Analysis Toolbox*, <http://thunderbox.uwaterloo.ca/~fmilano>.